

3/4" CEMENT PLASTER  
PER SEALED CLADDING  
SYSTEM  
12 MIL (min) DRYLOK  
EXTREME COATING

CASING OR OTHER STUCCO  
STOPS TO BE 1.5" MINIMUM  
ABOVE THE FINISHED  
DECKING MATERIAL

WOOD FRAME CONSTR.  
SELF-ADHERED FLASHING  
BY LAPPING DOWN  
OVER RIM JOIST AND UP  
WALL BY 6 IN. MINIMUM

SEAL TOPS OF JOISTS  
UNDER DECKING

WEATHER RESISTIVE  
BARRIER COVERS FLASHING

DOOR ROUGH OPENING  
FLASHING WRAP FULL  
JAMB AND HEADER

THRESHOLD PAN IS RECOMMENDED  
IF NO PAN IS USED, SET THRESHOLD  
IN SOLID SEALANT BED PER THE SEALED  
CLADDING SYSTEM DESIGN MANUAL

HATCH PATTERNS 1, 2 AND 3  
ARE SAME SELF-ADHERED FLASHING  
MATERIAL - INSTALL IN SEQUENCE  
HATCH PATTERN "1" TURNS UP 2"

SUBFLOOR

RIM JOIST

SCS 07\_02 SELF-ADHERED FLASHING  
EXTERIOR DOOR WITH DECK

Note:  
Details to be used in conjunction with all  
applicable provisions contained in the  
Sealed Cladding System Design Manual.

Sealed Cladding System

07/01/2020

SCS 07\_02